



City of Webster, Texas

FIRE LANE STANDARDS

(1) REQUIREMENTS FOR DESIGNATION OF FIRE LANES SHALL BE AS FOLLOWS:

(A). PAINTING

EACH FIRE LANE SHALL BE CONTINUOUSLY MARKED WITH RED PAINT, EITHER ON THE CURB OR, WHERE THE CURBS ARE NOT PRESENT, WITH A CONTINUOUS LINE NOT LESS THAN 4 INCHES WIDE. ON THE RED PAINTED SURFACES, THE WORDING "FIRE LANE" – "NO PARKING" IN WHITE LETTERS 3 INCHES HIGH SHALL BE CONSPICUOUSLY AND LEGIBLY MARKED AND APPLIED AT EACH END AND AT LEAST EVERY 25 FEET.

(B). SIGNAGE

FIRE LANE SIGNS MAY BE INSTALLED INDICATING A FIRE LANE IF ROADWAY OR PAVEMENT CONDITIONS ARE SUCH WHEN PAINTING THE FIRE LANE ON THE ROADWAY WILL BE IMPRACTICAL OR DIFFICULT TO RECOGNIZE. FIRE LANE SIGNS APPROVED BY THE FIRE MARSHAL SHALL BE INSTALLED NO LOWER THAN 6 FEET OR NO HIGHER THAN 7 FEET ABOVE GROUND AS MEASURED FROM THE BOTTOM OF THE SIGN. A FIRE LANE SIGN SHALL BE INSTALLED AT EACH END OF THE FIRE LANE WITH ARROWS POINTING TOWARD EACH OTHER. AN ADDITIONAL SIGN WITH THE ARROWS POINTING IN BOTH DIRECTIONS SHALL BE INSTALLED EVERY 50 FEET ALONG THE FIRE LANE IF SUCH A LANE IS LONGER THAN 100 FEET. THERE SHALL NOT BE LESS THAN TWO SIGNS IN EACH CONTINUOUS FIRE LANE. FURTHER, APPROVED FIRE LANE SIGNS SHALL BE PLACED AT THE END OF EACH PARKING ROW THAT IS WITHIN 25 FEET AND ON THE OPPOSITE SIDE OF A DRIVE THAT IS A FIRE LANE.

